

CERTIFICATE

of constancy of performance

1922 - CPR - 0566

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Pillar fire hydrants

DN 80 (outlet flange size - 2.0"; Kv=117,739) **PN 10/16;**

DN 100 (outlet flange size 2.5"; Kv=147,099) **PN 10/16;**

DN 150 (outlet flange size 4.0"; Kv= 372,362; Kv= 367,429) **PN 10/16**

placed on the market under the name or trade mark of

YAKACIK VALF SAN. VE TİC. A.Ş.

**Deri Organize San. Bölgesi, Tabak Sk., No:4, No.7-2 Özel Parsel,
Tuzla, İstanbul, Türkiye**

and produced in the manufacturing plant of

YAKACIK VALF SAN. VE TİC. A.Ş.


**Deri Organize San. Bölgesi, Tabak Sk., No:4, No.7-2 Özel Parsel,
Tuzla, İstanbul, Türkiye**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 14384:2005

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 01.03.2016 and will remain valid until 03.06.2027 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body. The certificate is supported through annual surveillance audit and is reissued after each surveillance audit. The validity of the certificate may be confirmed in the CE register at the web address www.dedal-bg.net.



Manager:

Anna Vasileva

Issued:
Burgas, 31 July 2023

Ref. No. 03-00

dipl. eng. Anna Vasileva